



July 23, 2021

Contract Identification Number : 2021-06-24-01
Name of Contract : **CONSTRUCTION OF ACADEMIC BUILDING III**
 (NEGOTIATED PROCUREMENT-TWO FAILED BIDDINGS)
Location of the Contract/Project : Cogon, Dipolog City

Supplemental/Bid Bulletin

Addendum No. 2

This Addendum No. 2 is issued to modify or amend an item in the Bidding Documents. This shall form an integral part of the Bidding Documents, to wit:

Particulars	References	Amendment/Addendum
1. Third Floor Work Description	SCOPE OF WORK II. PROJECT DESCRIPTION AND LOCATION Paragraph 4	Omitted Items From: It will also include complete filing of exterior and interior CHB with plastering, provision of electrical conduits, wiring, ICT cables, sanitary/drainage and potable water line piping and fire protection at the Third Floor. To: It will also include complete filing of exterior CHB with plastering at the Third Floor
2. Floor Elevation	SCOPE OF WORK III. Scope of Work Item 1. Design	Clarification 1 st , 2 nd and 3 rd Floor Elevation shall be 3.60m. Basement elevation shall be 3.20m. Floor elevations are not final and subject to change during Design Stage of project implementation.
3. Excavation	SCOPE OF WORK III. Scope of Work Item 2.d. Construction; Site Works	Additional scope of work This work item shall include handling, transportation and disposal of excavated materials at the Contractor's cost.
4. Fire Sprinkler System Pipe and fittings	SCOPE OF WORK III. Scope of Work Item 2.h.ii Construction; Mechanical Works- Fire Sprinkler System	Deletion ii. Installation of pipes and fittings cross main from riser to each sprinkler head drop nipple, drain line, valves, gauge and other necessary fittings at 3rd Floor.
5. Electrical works at 3rd Floor	SCOPE OF WORK III. Scope of Work Item 2.i.ii Construction; Electrical Works	Deletion From: ii. Installation and laying out of cables, wires, race-ways/cable trays and conduits at Basement, 1 st , 2 nd & 3 rd Floor. Third Floor cable installation shall be laid out thru