



July 19, 2021

Contract Identification Number : 2021-06-24-01
Name of Contract : **CONSTRUCTION OF ACADEMIC BUILDING III**
 (NEGOTIATED PROCUREMENT-TWO FAILED BIDDINGS)
Location of the Contract/Project : **Cogon, Dipolog City**

Supplemental/Bid Bulletin

Addendum No. 1

This Addendum No. 1 is issued to modify or amend an item in the Bidding Documents. This shall form an integral part of the Bidding Documents, to wit:

Particulars	References	Amendment/Addendum
1. Ceiling Material	SCOPE OF WORK III. Scope of Work Item 1. Design- Ceilings on all floors shall be made of Gypsum Board.	Additional Specification From: Ceiling on all floors shall be made of Gypsum Board. To: Ceiling on all floors shall be made of Gypsum Board or Fiber Cement Board (Hardiflex or approved equal)
2. Basement Waterproofing	SCOPE OF WORK Item III.1.d. Design; Basement Construction	Additional Specification From: Integral waterproofing (Sika Cement Admixtures) To: Integral waterproofing (Sika Cement Admixtures) - Sika Control WT-220 PH From: Application of cold applied waterproof liner To: Application of cold applied waterproof liner - MACBARRR Water Proofing Liner
3. Fire Escape Door	SCOPE OF WORK III. Scope of Work Item 1.e. Design; Doors and Windows -Fire Escape door shall be provided with panic device that conforms to the requirements of the Fire Code of the Philippines.	Clarification This provision is only applicable if required by Bureau of Fire Protection (BFP)
4. Painting Brand	SCOPE OF WORK III. Scope of Work Item 1.i. Design; Painting	Additional Specification Shall be Boysen or approved equal
5. Survey and Test	SCOPE OF WORK III. Scope of Work Item 3.II Bill of Quantities; Site Work	Clarification To conduct Soil Boring Test